

Page : 1

Revised edition no : 0

Date : 6 / 12 / 2016

Supersedes: 0/0/0

**Propane** 

SDS\_C3H8









### SECTION 1. Identification of the substance/mixture and of the company/undertaking

### 1.1. Product identifier

Trade name : Propane

SDS Nr : SDS\_C3H8

Chemical description : Propane

CAS No :74-98-6 EC No :200-827-9 Index No :601-003-00-5 : 01-2119486944-21-

**Registration-No.** : 01-2119486944

Chemical formula : C3H8

## 1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.

Test gas/Calibration gas. Laboratory use. Chemical reaction / Synthesis.

Use as a fuel.

Contact supplier for more information on uses.

# 1.3. Details of the supplier of the safety data sheet

Company identification : BUZWAIR INDUSTRIAL GASES FACTORIES

PO Box 319 Doha Qatar

1.4. Emergency telephone number

Emergency telephone number : +974 4451 6976

### **SECTION 2. Hazards identification**

### 2.1. Classification of the substance or mixture

## Hazard Class and Category Code Regulation EC 1272/2008 (CLP)

• Physical hazards : Flammable gases - Category 1 - Danger - (CLP : Flam. Gas 1) - H220 Gases under pressure - Liquefied gas - Warning - (CLP : Press. Gas) - H280

Classification EC 67/548 or EC 1999/45

: F+; R12

### 2.2. Label elements

# Labelling Regulation EC 1272/2008 (CLP)

Hazard pictograms





PO Box 319 Doha Qatar



Page: 2

Revised edition no: 0 Date: 6 / 12 / 2016

Supersedes: 0/0/0

# **Propane**

SDS\_C3H8

### **SECTION 2. Hazards identification (continued)**

· Hazard pictograms code : GHS02 - GHS04

 Signal word : Danger

· Hazard statements : H220 - Extremely flammable gas.

H280 - Contains gas under pressure; may explode if heated.

· Precautionary statements

: P210 - Keep away from heat/sparks/open flames/hot surfaces. - No smoking. - Prevention : P377 - Leaking gas fire : Do not extinguish, unless leak can be stopped safely. - Response

P381 - Eliminate all ignition sources if safe to do so.

- Storage : P403 - Store in a well-ventilated place.

2.3. Other hazards

: Contact with liquid may cause cold burns/frostbite.

### SECTION 3. Composition/information on ingredients

### 3.1. Substance / 3.2. Mixture

Substance.

Substance name		Contents	CAS No EC No Index No Registration no	Classification(DSD)	Classification(CLP)
Propane	:	100 %	74-98-6 200-827-9 601-003-00-5	F+; R12	Flam. Gas 1 (H220) Press. Gas Liquefied (H280)

01-2119486944-21-

Contains no other components or impurities which will influence the classification of the product.

- 1: Listed in Annex IV / V REACH, exempted from registration.
- \* 2: Registration deadline not expired.
- \* 3: Registration not required: Substance manufactured or imported < 1t/y. Full text of R-phrases see section 16. Full text of H-statements see section 16.

### **SECTION 4. First aid measures**

### 4.1. Description of first aid measures

- Inhalation Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.

: For liquid spillage - flush with water for at least 15 minutes. - Skin contact

- Eye contact : Immediately flush eyes thoroughly with water for at least 15 minutes.

- Ingestion : Ingestion is not considered a potential route of exposure.

# 4.2. Most important symptoms and effects, both acute and delayed

: In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/

consciousness. Victim may not be aware of asphyxiation.

In low concentrations may cause narcotic effects. Symptoms may include dizziness,

headache, nausea and loss of co-ordination.

# 4.3. Indication of any immediate medical attention and special treatment needed

: None.

**BUZWAIR INDUSTRIAL GASES FACTORIES** PO Box 319 Doha Qatar



Page: 3

Revised edition no: 0 Date: 6 / 12 / 2016

Supersedes: 0/0/0

# **Propane**

SDS\_C3H8

### **SECTION 5. Firefighting measures**

### 5.1. Extinguishing media

- Suitable extinguishing media : Water spray or fog. Dry powder.

- Unsuitable extinguishing media : Do not use water jet to extinguish.

Carbon dioxide.

### 5.2. Special hazards arising from the substance or mixture

: Exposure to fire may cause containers to rupture/explode. Specific hazards **Hazardous combustion products** : Incomplete combustion may form carbon monoxide.

### 5.3. Advice for fire-fighters

Specific methods : Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat

radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases fro

If possible, stop flow of product.

Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive

re-ignition may occur. Extinguish any other fire.

Use water spray or fog to knock down fire fumes if possible.

Special protective equipment for fire

fighters

In confined space use self-contained breathing apparatus.

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire

fighters.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full face mask.

Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves for

firefighters.

### SECTION 6. Accidental release measures

# 6.1. Personal precautions, protective equipment and emergency procedures

: Wear self-contained breathing apparatus when entering area unless atmosphere is proved to

be safe.

Consider the risk of potentially explosive atmospheres.

Try to stop release. Evacuate area.

Ensure adequate air ventilation. Eliminate ignition sources.

Prevent from entering sewers, basements and workpits, or any place where its accumulation

can be dangerous.

# 6.2. Environmental precautions

: Try to stop release.

### 6.3. Methods and material for containment and cleaning up

: Ventilate area

### 6.4. Reference to other sections

: See also sections 8 and 13.

# SECTION 7. Handling and storage

### 7.1. Precautions for safe handling

Safe use of the product

Only experienced and properly instructed persons should handle gases under pressure. The substance must be handled in accordance with good industrial hygiene and safety procedures.

Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt.

Take precautionary measures against static discharge.

Purge air from system before introducing gas. Keep away from ignition sources (including static discharges).

Do not smoke while handling product.

### **BUZWAIR INDUSTRIAL GASES FACTORIES**

PO Box 319 Doha Qatar



Page : 4

Revised edition no : 0 Date : 6 / 12 / 2016

Supersedes : 0 / 0 / 0

# **Propane**

SDS\_C3H8

## **SECTION 7. Handling and storage (continued)**

Assess the risk of potentially explosive atmospheres and the need for explosion-proof

equipment.

Consider the use of only non-sparking tools.

Ensure the complete gas system was (or is regularily) checked for leaks before use.

Consider pressure relief device(s) in gas installations.

Safe handling of the gas receptacle : Refer to supplier's container handling instructions.

Suck back of water into the container must be prevented.

Do not allow backfeed into the container.

Protect cylinders from physical damage; do not drag, roll, slide or drop.

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.)

designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall

or bench or placed in a container stand and is ready for use.

If user experiences any difficulty operating cylinder valve discontinue use and contact

supplier.

Never attempt to repair or modify container valves or safety relief devices.

Damaged valves should be reported immediately to the supplier.

Keep container valve outlets clean and free from contaminants particularly oil and water. Replace valve outlet caps or plugs and container caps where supplied as soon as container is disconnected from equipment.

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.

### 7.2. Conditions for safe storage, including any incompatibilities

: Observe all regulations and local requirements regarding storage of containers.

Keep container below 50°C in a well ventilated place.

Segregate from oxidant gases and other oxidants in store. Containers should be stored in the vertical position and properly secured to prevent toppling. Stored containers should be periodically checked for general condition and leakage. Container valve guards or caps should be in place. Store containers in location free from fire risk and away from sources of heat and ignition. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.

Containers should not be stored in conditions likely to encourage corrosion. Keep away from

combustible materials.

### 7.3. Specific end use(s)

: None.

# SECTION 8. Exposure controls/personal protection

### 8.1. Control parameters

**Occupational Exposure Limits** 

Propane

: AGW (8h) - Germany [mg/m³] TRGS 900 : 1800

: AGW (8h) - Germany [ppm] TRGS 900 : 1000

: Exceeding factor AGW - Germany TRGS 900 : 4

: MAK (AU) Tagesmittelwert (ml/m3): 1000

: MAK (AU) Tagesmittelwert (mg/m³): 1800 : MAK (AU) Kurzzeitwerte (ml/m³): 2000

: MAK (AU) Kurzzeitwerte (mg/m³): 3600

: Grænserværdier (DK) (ppm) : 1000

: HTP-värden (FI) - 8 H - [ppm] : 800

: HTP-värden (FI) - 8 H - [mg/m³] : 1500

: HTP-värden - 15min - [ppm] : 1100

: Grænserværdier (DK) mg/m³: 1800

: HTP-värden - 15min - [mg/m³] : 2000

PO Box 319 Doha Qatar



Page: 5

Revised edition no: 0 Date: 6 / 12 / 2016

Supersedes: 0/0/0

# **Propane**

SDS\_C3H8

### SECTION 8. Exposure controls/personal protection (continued)

: Grenseverdi (NO) 8 timers [ppm] : 500 : Grenseverdi (NO) 8 timers [mq/m³] : 900

: VLE-CH [ma/m31: 7200 : VLE-CH [ppm]: 4000 : VME-CH [mg/m3]: 1800

: 8-Hour TWA (PL) (NDS) (mg/m3): 1800 : Valori Limite di Soglia (IT) 8 ore [ppm] : 1000

: TLV-TWA (Belgium) (ppm): 1000

: Valoare limita maxima (RO) 8 ore [mg/m³] : 1400 : Valoare limita maxima (RO) 8 ore [ppm]: 778

: Valoare limita maxima (RO) Termen scurt 15min [mg/m³]: 1800 : Valoare limita maxima (RO) Termen scurt 15min [ppm] : 1000

: TWA BG 8h [mg/m3]: 1800 : TWA EE 8h [ppm]: 1000 : TWA EE 8h [mg/m3]: 1800 : TLV@ -TWA [ppm] : 2500

DNEL: Derived no effect level (

Workers)

No data available

PNEC: Predicted no effect

concentration

: No data available.

### 8.2. Exposure controls

8.2.1. Appropriate engineering

controls

: Systems under pressure shoud be regularily checked for leakages. Ensure exposure is below occupational exposure limits (where available). Gas detectors should be used when flammable gases/vapours may be released.

Provide adequate general and local exhaust ventilation. Consider work permit system e.g. for maintenance activities

The substance is not classified for human health hazards or for environment effects and it is not PBT or vPvB so that no exposure assessment or risk characterisation is required. For tasks where the intervention of workers is required, the substance must

e.g. personal protective equipment

8.2.2. Individual protection measures, : A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.

The following recommendations should be considered: PPE compliant to the recommended EN/ISO standards should be selected.

· Eye/face protection Wear safety glasses with side shields.

Wear safety glasses with side shields or goggles when transfilling or breaking transfer

connections

Standard EN 166 - Personal eye-protection.

Skin protection

: Wear working gloves when handling gas containers. - Hand protection

Standard EN 388 - Protective gloves against mechanical risk.

: Wear safety shoes while handling containers. - Other

Consider the use of flame resistant anti-static safety clothing.

Standard EN ISO 20345 - Personal protective equipment - Safety footwear.

Standard EN ISO 14116 - Limited flame spread materials.

Standard EN ISO 1149-5 - Protective clothing: Electrostatic properties.

: Gas filters may be used if all surrounding conditions e.g. type and concentration of the · Respiratory protection

contaminant(s) and duration of use are known.

Recommended: Filter AX (brown).

Consult respiratory device supplier's product information for the selection of the appropriate

Standard EN 14387 - Gas filter(s), combined filter(s) and full face mask - EN 136. Gas filters do not protect against oxygen deficiency.

 Thermal hazards : None necessary.

PO Box 319 Doha Qatar



Page : 6

Revised edition no : 0

Date : 6 / 12 / 2016

Supersedes: 0/0/0

# **Propane**

SDS\_C3H8

### SECTION 8. Exposure controls/personal protection (continued)

8.2.3. Environmental exposure

controls

: Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for

specific methods for waste gas treatment.

### **SECTION 9. Physical and chemical properties**

# 9.1. Information on basic physical and chemical properties

**Appearance** 

Physical state at 20°C / 101.3kPa : Gas.
Colour : Colourless.

**Odour** : Sweetish. Poor warning properties at low concentrations.

Stenchant often added.

**Odour threshold** : Odour threshold is subjective and inadequate to warn for overexposure.

**pH value** : Not applicable.

Molar mass [g/mol] : 44

Melting point [°C] : -188

Boiling point [°C] : -42.1

Critical temperature [°C] : 97

Flash point [°C] : Not applicable for gases and gas-mixtures.

Evaporation rate (ether=1) : Not applicable for gases and gas-mixtures.

Flammability range [vol% in air] : 1.7 - 10.8

Vapour pressure [20°C] : 8.3 bar

Relative density, gas (air=1) : 1.5

Relative density, liquid (water=1) : 0.58

Solubility in water [mg/l] : 75

Partition coefficient n-octanol/water [ : 2.36

log Kow]

Auto-ignition temperature [°C] : 470

Viscosity at 20°C [mPa.s]: Not applicable.Explosive Properties: Not applicable.Oxidising Properties: None.

9.2. Other information

Other data : Gas/vapour heavier than air. May accumulate in confined spaces, particularly at or below

ground level.

## **SECTION 10. Stability and reactivity**

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions

: May react violently with oxidants. Can form explosive mixture with air.

10.4. Conditions to avoid

: Keep away from heat/sparks/open flames/hot surfaces. – No smoking.

10.5. Incompatible materials

: Air, Oxidiser.

For additional information on compatibility refer to ISO 11114.

**BUZWAIR INDUSTRIAL GASES FACTORIES** 

PO Box 319 Doha Qatar



Page : 7
Revised edition no : 0

Date: 6 / 12 / 2016

Supersedes : 0 / 0 / 0

# **Propane**

SDS\_C3H8

### SECTION 10. Stability and reactivity (continued)

### 10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be produced.

### **SECTION 11. Toxicological information**

### 11.1. Information on toxicological effects

Acute toxicity : No known toxicological effects from this product.

: No known effects from this product. Skin corrosion/irritation Serious eye damage/irritation : No known effects from this product. Respiratory or skin sensitisation : No known effects from this product. Carcinogenicity : No known effects from this product. Germ cell mutagenicity : No known effects from this product. Reproductive toxicity : No known effects from this product. STOT-single exposure : No known effects from this product. STOT-repeated exposure : No known effects from this product. **Aspiration hazard** : Not applicable for gases and gas-mixtures.

## **SECTION 12. Ecological information**

### 12.1. Toxicity

EC50 48h - Daphnia magna [mg/l] : 27.1 EC50 72h Algae [mg/l] : 11.9 LC50-96 h - fish [mg/l] : 49.9

### 12.2. Persistence and degradability

: The substance is biodegradable. Unlikely to persist.

### 12.3. Bioaccumulative potential

: Not expected to bioaccumulate due to the low log Kow ( log Kow < 4).

Refer to section 9.

### 12.4. Mobility in soil

: Because of its high volatility, the product is unlikely to cause ground or water pollution.

### 12.5. Results of PBT and vPvB assessment

: Not classified as PBT or vPvB.

## 12.6. Other adverse effects

Effect on ozone layer : None.

Effect on the global warming : No known effects from this product.

**BUZWAIR INDUSTRIAL GASES FACTORIES** 

PO Box 319 Doha Qatar



Page : 8

Revised edition no : 0

Date : 6 / 12 / 2016

Supersedes: 0/0/0

# **Propane**

SDS\_C3H8

## **SECTION 13. Disposal considerations**

### 13.1. Waste treatment methods

: Do not discharge into areas where there is a risk of forming an explosive mixture with air.

Waste gas should be flared through a suitable burner with flash back arrestor. Do not discharge into any place where its accumulation could be dangerous.

Refer to the EIGA code of practice Doc.30 "Disposal of Gases"", downloadable at http://www.

eiga.org for more guidance on suitable disposal methods.

Ensure that the emission levels from local regulations or operating permits are not exceeded.

List of hazardous wastes

: 16 05 04: Gases in pressure containers (including halons) containing dangerous substances.

13.2. Additional information

: None.

## **SECTION 14. Transport information**

UN number : 1978

Labelling ADR, IMDG, IATA



: 2.1 : Flammable gases

Land transport (ADR/RID)

H.l. nr : 23

UN proper shipping name : PROPANE

Transport hazard class(es) : 2
Classification code : 2 F
Packing Instruction(s) : P200

Tunnel Restriction : B/D Tank carriage: Passage forbidden through tunnels of category B, C, Dand E;Other

carriage: Passage forbidden through tunnels of category D and E

Environmental hazards : None.

Sea transport (IMDG)

Proper shipping name : PROPANE

Class : 2.1

Emergency Schedule (EmS) - Fire : F-D

Emergency Schedule (EmS) - Spillage : S-U

Packing instruction : P200

IMDG-Marine pollutant : No

Air transport (ICAO-TI / IATA-DGR)

Proper shipping name (IATA) : PROPANE

**Class** : 2.1

Passenger and Cargo Aircraft : DO NOT LOAD IN PASSENGER AIRCRAFT.

Cargo Aircraft only : Allowed.

Packing instruction - Cargo Aircraft : 200

only

#### Special precautions for user

: Avoid transport on vehicles where the load space is not separated from the driver's

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.

In case of emergency: +974 4451 6976

Before transporting product containers:

- Ensure that containers are firmly secured.
- Ensure cylinder valve is closed and not leaking.
- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.
- Ensure valve protection device (where provided) is correctly fitted.



Page: 9

Revised edition no: 0 Date: 6 / 12 / 2016

Supersedes: 0/0/0

# **Propane**

SDS\_C3H8

### **SECTION 14. Transport information (continued)**

- Ensure there is adequate ventilation.

Transport in bulk according to Annex : Not applicable. II of MARPOL 73/78 and the IBC Code

## **SECTION 15. Regulatory information**

### 15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

**EU** legislation

Restrictions on use : None. Seveso directive 96/82/EC : Listed.

**National legislation** 

**National legislation** : Ensure all national/local regulations are observed.

15.2. Chemical safety assessment

: CSA has been carried out. Refer to section 8.2.

### **SECTION 16. Other information**

Indication of changes : Revised safety data sheet in accordance with commisssion regulation (EU) No 453/2010.

: Ensure operators understand the flammability hazard. Training advice

The hazard of asphyxiation is often overlooked and must be stressed during operator training.

List of full text of R-phrases in section: R12: Extremely flammable.

List of full text of H-statements in

: H220 - Extremely flammable gas.

section 3.

H280 - Contains gas under pressure; may explode if heated.

**Further information** This Safety Data Sheet has been established in accordance with the applicable European

Union legislation.

**DISCLAIMER OF LIABILITY** Whilst proper care has been taken in the preparation of this document, no liability for injury or

damage resulting from its use can be accepted. Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out. Details given in this document are believed to be correct at the time of going to press.

End of document

In case of emergency: +974 4451 6976

PO Box 319 Doha Qatar